

## Technische Parameters LSQWRH Series Units (R407C)

Unit: kW

Type	T <sub>cond</sub>	35°		40°		45°		50°		55°		60°	
	T <sub>verd</sub>	Q	P	Q	P	Q	P	Q	P	Q	P	Q	P
25	-5°	16.6	4.45	15.7	4.99	14.8	5.53	13.7	6.22	12.7	6.91	11.1	7.79
	0°	20.5	4.46	19.4	5.01	18.3	5.55	17.1	6.24	15.9	6.93	14.5	7.80
	5°	25.0	4.45	23.7	5.00	22.5	5.55	21.0	6.25	19.6	6.94	17.9	7.81
	10°	30.1	4.42	28.7	4.97	27.2	5.52	25.5	6.22	23.9	6.92	22.0	7.80
33	-5°	28.0	5.79	27.5	6.54	27.0	7.28	26.6	8.25	26.2	9.22	25.4	10.4
	0°	33.0	5.80	32.4	6.54	31.7	7.27	31.0	8.23	30.3	9.19	29.8	10.4
	5°	38.9	5.78	38.0	6.51	37.0	7.23	36.1	8.19	35.1	9.14	34.2	10.4
	10°	45.5	5.73	44.3	6.45	43.1	7.17	41.9	8.12	40.6	9.06	39.3	10.3
43	-5°	36.4	7.61	35.8	8.50	35.2	9.39	34.6	10.5	34.0	11.6	25.4	13.0
	0°	43.1	7.66	42.2	8.56	41.3	9.45	40.4	10.6	39.5	11.7	31.3	13.1
	5°	50.7	7.68	49.6	8.58	48.4	9.47	47.1	10.6	45.8	11.7	37.2	13.1
	10°	59.5	7.68	58.0	8.58	56.5	9.48	54.9	10.6	53.2	11.7	44.2	13.1
50	-5°	33.4	8.78	31.6	9.84	29.8	10.9	27.8	12.3	25.7	13.7	22.6	15.4
	0°	41.0	8.82	38.9	9.91	36.8	11.0	34.4	12.4	32.0	13.8	29.3	15.5
	5°	49.8	8.85	47.4	9.93	44.9	11.0	42.1	12.4	39.2	13.8	36.0	15.5
	10°	59.8	8.85	57.0	9.93	54.1	11.0	50.8	12.4	47.5	13.8	43.7	15.6
68	-5°	45.3	12.1	43.0	13.3	40.5	14.8	37.9	16.4	35.3	18.2	32.6	20.3
	0°	55.8	12.2	53.0	13.5	50.0	15.0	47.0	16.6	43.8	18.4	40.6	20.5
	5°	67.9	12.4	64.6	13.7	61.1	15.2	57.5	16.8	53.8	18.7	49.9	20.8
	10°	81.8	12.5	78.0	13.9	73.9	15.4	69.7	17.0	65.3	18.9	60.7	21.1
82	-5°	55.4	14.3	53.0	16.0	50.4	17.9	47.5	19.9	44.4	22.1	41.1	24.5
	0°	67.5	14.5	64.8	16.3	61.7	18.2	58.2	20.2	54.5	22.5	50.6	24.9
	5°	81.6	14.7	78.4	16.5	74.7	18.5	70.7	20.6	66.4	22.9	61.7	25.4
	10°	97.8	14.9	94.1	16.8	89.8	18.8	85.2	20.9	80.1	23.2	74.7	25.8

Nota Bene: Q—Koeling Capaciteit;

P—Input Power;

Verwarmingsvermogen=Q+P

T<sub>cond</sub>=condensator Temperatuur

T<sub>verd</sub>=Verdamper Temperatuur

## Technische Parameters LSQWRH Series Units (R134 A)

单位: kW

Type	T <sub>cond</sub>	35°		40°		45°		50°		55°		60°	
	T <sub>verd</sub>	Q	P	Q	P	Q	P	Q	P	Q	P	Q	P
18	-5°	11.7	3.14	11.1	3.52	10.6	3.90	9.92	4.37	9.26	4.84	8.12	5.41
	0°	14.4	3.14	13.7	3.53	13.1	3.91	12.3	4.38	11.5	4.85	10.6	5.42
	5°	17.5	3.12	16.7	3.52	15.9	3.91	15.0	4.39	14.1	4.86	13.1	5.44
	10°	21.0	3.10	10.1	3.51	19.2	3.91	18.1	4.39	17.1	4.86	15.9	5.44
23	-5°	15.1	4.06	14.4	4.55	13.6	5.03	12.8	5.65	11.9	6.27	10.3	7.03
	0°	18.7	4.07	17.8	4.56	16.9	5.04	15.9	5.65	14.9	6.27	13.7	7.03
	5°	22.8	4.07	21.8	4.56	20.7	5.04	19.6	5.65	18.4	6.27	17.1	7.03
	10°	27.5	4.05	26.4	4.54	25.2	5.02	23.8	5.64	22.4	6.25	20.9	7.01
30	-5°	20.0	5.37	19.1	5.95	18.0	6.52	16.9	7.25	15.8	7.97	14.0	8.90
	0°	24.7	5.41	23.6	5.99	22.4	6.57	21.1	7.30	19.8	8.03	18.4	8.94
	5°	30.2	5.43	28.9	6.02	27.5	6.60	26.0	7.34	24.5	8.07	22.8	8.99
	10°	36.4	5.42	34.9	6.01	33.3	6.60	31.6	7.35	29.8	8.09	27.9	9.02
34	-5°	22.6	6.20	21.5	6.86	20.3	7.52	19.1	8.36	17.8	9.19	15.9	10.2
	0°	27.9	6.24	26.6	6.91	25.3	7.57	23.9	8.42	22.4	9.26	20.8	10.3
	5°	34.1	6.26	32.6	6.94	31.1	7.61	29.4	8.46	27.7	9.31	25.8	10.4
	10°	41.2	6.25	39.5	6.94	37.7	7.62	35.7	8.48	33.7	9.33	31.5	10.4
47	-5°	30.8	8.47	29.3	9.07	27.6	9.95	25.8	11.2	24.1	12.4	22.2	13.8
	0°	38.5	8.44	36.1	9.08	34.0	9.98	40.0	11.3	29.8	12.4	27.6	13.9
	5°	46.9	8.46	44.0	9.10	41.6	10.1	39.2	11.3	36.6	12.5	33.9	13.9
	10°	57.2	8.46	53.1	9.10	50.3	10.2	47.4	11.3	44.5	12.6	41.3	14.1
56	-5°	37.8	9.72	36.1	10.9	34.3	12.3	32.4	13.7	30.2	15.2	28.0	21.3
	0°	46.0	9.75	44.1	10.9	42.1	12.3	39.7	13.8	37.1	15.2	34.5	21.4
	5°	55.5	9.77	53.4	11.0	50.8	12.3	48.1	13.8	45.2	15.2	42.0	21.5
	10°	66.6	9.79	64.0	11.1	58.0	12.4	58.1	13.9	54.5	15.3	50.9	21.5

Nota Bene: Q——Koeling Capaciteit;

P——Input Power;

Verwarmingsvermogen=Q+P

 T<sub>cond</sub>=condensator Temperatuur

 T<sub>verd</sub>=Verdamper Temperatuur